

30.05.2018

**INVITATION OF BIDS FOR FIXING RATE CONTRACT FOR SUPPLY OF
LIQUID MEDICAL OXYGEN, MEDICAL GRADE OXYGEN, NITROUS
OXIDE, CARBON-DI-OXIDE AND NITRIC OXIDE IN CYLINDERS
TENDER NO. 294/LOP/DME/TNMSC/ENGG/2018 DATED 20.04.2018
CORRIGENDUM**

A. The following is the amendment issued :-

SI. No.	Instead of	Read as
1.	Existing tender document	Revised tender document at Annexure A

B. The following clarification are issued :-

SI. No.	Points raised	Clarification
1.	Requested to clarify whether the hospital will provide suitable area in accordance with PESO norms as LMOX tanks require normally 15 mt * 9 mt area	The space for installation of LMOX plant will be provided by the institution as per requirement.
2.	Requested to clarify, if the site is not suitable for liquid medical installation governed by CCOE, can the mode of supply be only in cylinders.	Obtaining CCOE license for new installation is the responsibility of the supplier.
3.	Requested to include the technical requirement such as telemetry system, Mandatory alarm signals, regulators and safety valves	Uninterrupted supply of liquid oxygen and gases should be provided by the supplier. The installation of telemetry system, alarm system and safety devices

SI. No.	Points raised	Clarification
		may be provided by the supplier if required and found useful for their operation.

All other terms and conditions of the tender remain unaltered.

The above corrigendum with annexure forms part of the tender document. The bidder shall attach a copy of this corrigendum duly signed by their authorized signatory in their bid.

**Sd/-
General Manager (Equip)**